

**Q** How to do pinging test to the connected devices during operation?


**A** First, create a Batch(.bat) file with device IP address in it. Then, run this Batch file by the Script feature of SCADA.

1. Create a Batch file by using Notepad on Window.
2. Enter a content “ping + IP address of linked device” into Batch file.

Ex) ping 192.168.0.115


3. Open SCADA CIMON-D, and create a statement at Script feature as below. The Batch file path must be designated.

```
Id = Shell("C:\ip.bat"",3)
```



4. Create a button to call the created Script.

Ex) ping



5. Run CIMON-X, and click the ping test button to run the created Script.

